

Hotel emergency generator monthly test log

Generator model

Engine model

Date installed

Standby kW nameplate rating

30% of standby rating

Fuel type

Normal operating temp

Monthly testing log

	Time meter reading start and end	Transfer switch inspection and test	Battery specific gravity	Oil pressure and operating temp	Load kW	Tested by
January						
February						
March						
April						
May						

June

July

August

September

October

November

December

Comments