In order to submit this form, you should open it with Adobe Acrobat Reader.

Hotel emergency light test log

For battery-operated emergency lights

Facility name

Year

Enter the year for which the testing is being completed.

A 30-second monthly activation test and a 30-minute annual test must be performed on each of the facility's battery-operated mergency lights. Indicate the typle of test conducted and initial each monthly entry. M=30-second test. A=30-minute test.

	Date installed	January	February	March	April	May	June	July
Unit location								
Unit location								
Unit location								
Unit location								
Unit location								
Unit location								

	Date installed	August	September	October	November	December	Battery replaced
Unit location							
Unit location							
Unit location							
Unit location							
Unit location							
Unit location							